DOE Lessons Learned Template

Note: This Lessons Learned is also found in Appendix C- Fire Protection Readings

Title: Site Directives

Date: 07/07/05

Identifier: 2005-RF-24

Lessons Learned Statement: Revise Site Directives, Procedures, etc. as conditions

change.

Discussion of Activities: Rocky Flats Project Office realized that Standard Site Directives, Orders, etc. will need to be revised as conditions change from "business as usual" to a dynamic closure operating environment. Some examples of visible changes are:

- 1. Hot Work Permits- procedures need to change as the work shifts from periodic equipment cuts and welds toward frequent facility demolition situations,
- 2. Refueling procedures- as electricity shifts from being provided by the grid to ward all electricity from portable generators and the vehicle gas station is demolished,
- 3. Fire protection procedures- need to be developed for movable structures as these suddenly proliferate to replace permanent structures being demolished,
- 4. Overall site Fire Protection procedures- Needs will develop to be able to take fire protection systems out of service, but the site must still ensure life safety and appropriate property protection at all times, and
- 5. Potential needed revisions/amendments to the directive for the control of subcontractors, who typically have functioned under a less rigid safety and fire protection culture.

Analysis (May be incorporated into the Discussion):

Recommended Actions:

Estimated Savings/Cost Avoidance (if applicable):

Originator: Jeff McMillan

Contact: Bob Williams

Keywords: Site Directives